

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Meru school | 025 | 25-26

Dated: 09/06/2025

It is certified that an inspection team headed by Dr. Avinash Yadav with team

(Name of Officers with designation) from PFR Mariah JNP PHED inspected the Shri Chhotelal International School Mahadev P. Dadam Marichu Jaunpur (Name & Address) of the school on 09/06/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. WAT/JNP/134/2025-26 dated 07/06/2025 of Water Analysis Report

District - Jaunpur U.P. (PHED Lab)

..... certified that the Shri Chhotelal International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year 09/06/2026

अधिकारी अभियन्ता  
खण्ड कार्यालय

Signature with Seal: भूतर. प्रदेश. जल. विभाग. (ग्रममीण).....

Name : ..... जौनपुर .....

Designation : .....


Name & Address of the Office / Department : .....

To The Manager.....

(Name & Address of the Institution)

Shri Chhotelal International School Mariah JNP

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





## Water Analysis Report, District-Jaunpur, UTTAR PRADESH

Rept No	382		Date	07/06/2025	Page No	01
<b>Customer Details</b>						
Office Name and Address		SHRI CHHOTELAL INTERNATIONAL SCHOOL, MAHAMADPUR, DADARA, MARIAHU, JAUNPUR, U.P.				
Ref Letter No.		WAR/JNP/034/2025-26				
<b>Basic details of sample</b>						
District		JAUNPUR		Tehsil	MARIAHU	
Gram Panchayat		DADARA		Village	MAHAMADPUR	
Habitation		-		Location	MAHAMADPUR, DADARA, MARIAHU, JAUNPUR, U.P.	
Water Source		R O Water		Sample No.	Sample 5	
Quality of Sample		1000ml (Normal)		Date of S.C.	07/06/2025	
Receiving Date		07/06/2025		S. Collector	Mr. MOHIT KUMAR	
Sample Depositor		MRS. MANNA DEVI		Analysis Completion Date		07/06/2025
<b>Technical Data of Analysis</b>						
SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis	
			Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	
1	pH	7.31	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)	
2	Turbidity (NTU)	0.59	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)	
3	TDS. Mg/1	223	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)	
4	Chloride (as Cl), mg/1	10	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)	
5	Total Alkalinity (as Na <sub>2</sub> CO <sub>3</sub> ), mg/1	188	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)	
6	Total Hardness (as CaCO <sub>3</sub> ), mg/1	92	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)	
7	Calcium (as Ca), mg/1	16.8	75	200	IS 3025 (Part 40): 2019	
8	Magnesium (as Mg), mg/1	12.5	30	100	IS 3025 (Part 46): 2019	
9	Nitrate (as NO <sub>3</sub> ), mg/1	5	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO <sub>3</sub> (B.Ultraviolet Spectrophotometric Screening Method)	
10	Fluoride (as F), mg/1	0.324	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)	
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Ed 2017, 3500-Fe (B Phenanthroline Method)	
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021	
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622	

**Note:-**

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

  
Prepared by

Lab Technician

  
Authorized Signatory

Quality/Technical Manager